



**WEIL-McLAIN**

# **CGa, EG, EGH, PEG, and PFG Gas-Fired Boilers**

## **Addendum**

**This Addendum needs to be used in conjunction with the following documents:**

**P/N 550-101-009/0703 - GOLD CGa Gas-Fired Water Boiler - Boiler Manual**

**P/N 550-110-592/0703 - CGa, CGi, CGs, EG, EGH, LGB, PEG, PFG  
Gas Fired Boilers - User's Information Manual**

**P/N 550-110-646/0706 - EG, PEG, and EGH Series 4 Universal Control  
Systems (UCS) - Gas Control Supplement**

**P/N 550-110-032/0706 - EG-30 through 75 & PEG-30 through 65 Series 4  
Gas-Fired Boilers - Control Supplement - Standing Pilot**

**P/N 550-110-643/0605 - PFG Gas-Fired Water Boiler, Series 7 -  
Control Supplement - Universal Control Systems (UCS)**

This appliance may have been provided with a vent damper manufactured by Field Controls. Installation and service for these components are as prescribed in the manuals is identical to the Effikal damper. The wiring and operation of the vent dampers are identical.

Substitute the part numbers shown on the following table for the replacement automatic vent dampers shown on any of the manuals listed above.

Description				Part Number
Vent Damper	4"	CGa-25, CGa-3	Field Controls GVD-4	381-800-474
	5"	CGa-4, EG-30, EG-35, PEG-30, PEG-35	Field Controls GVD-5	381-800-475
	6"	CGa-5, CGa-6, EG-40, EG-45, PEG-40, PEG-45	Field Controls GVD-6	381-800-476
	7"	CGa-7, CGa-8, EG-50, EG-55, PEG-50, PEG-55, PFG-5	Field Controls GVD-7	381-800-477
	8"	EG-65, EG-75, PEG-65, PFG-6	Field Controls GVD-8	381-800-478
	9"	EGH-85, PFG-7, PFG-8	Field Controls GVD-9	381-800-445
	10"	EGH-95, EGH-105	Field Controls GVD-10	381-800-446
	12"	EGH-115, EGH-125	Field Controls GVD-12	381-800-447

Note: The part numbers shown here and in the boiler manuals are fully interchangeable. Either one may be used as a replacement.

Weil-McLain  
500 Blaine Street  
Michigan City, IN 46360-2388  
<http://www.weil-mclain.com>